


SEQUENCE OF OPERATION FOR HORN / STROBES IN RESIDENTIAL SLEEPING ROOMS BASED ON SMOKE DETECTOR ACTIVATION:

- NAC PANELS SERVING RESIDENT ROOMS SHALL HAVE TWO TRIGGER INPUTS SERVED BY
- ADDRESSABLE MODULES.
- 2. FACP SHALL BE PROGRAMMED SUCH THAT ACTIVATION OF A SLEEPING ROOM SMOKE DETECTOR WILL ACTIVATE THE HORN /STROBES WITHIN THAT ROOM AND THE FEW ROOMS THAT ARE ON THAT SAME NAC TRIGGER CIRCUIT. AS SUCH, NOT ALL RESIDENTIAL ROOMS WILL ALARM, BUT ONLY A FEW ROOMS.
- 3. NOTIFICATION DEVICES THROUGHOUT OTHER AREAS OF THE BUILDING WILL NOT ALARM UPON A SLEEPING ROOM SMOKE.



E7 SEQUENCE OF OPERATION NTS

FULLY SPRINKLERED

100% CONSTRUCTION DOCUMENTS

		CONSULT	'ANTS:			ARCHITECT / ENGINEERS:					Drawing Title FIRE ALARM RISERS			Project Title RENOVATE LEROY POND ARMY Project Number 564-341			Project Number	THOM DOCUMENTS
		Lacev			THIS IS NOT AN ORIGINAL SEALED	ARKANSAS			4500 Burrow Drive		TINE ALANVINISERS			RESERVE CENTER FOR MENTAL HEALTH RESIDENTIAL REHABILITATION TREATMENT / POLICE TRAINING			Building Number	Office of Facilities
		Engineering, LLO 17 BUSINESS PRK DR		DOCUMENT. AN ORIGINAL SEA AVAILABLE AT 17	BUSINESS PARK H1341	PROPESSIONAL ENGINEER	TARGART	DT	North Little Rock, AR 72116 Phone: 501-758-7443 Fax: 501-753-7309	5	Approved: Project Director			Location FAYETTEVILLE, ARKAI				
Revisions:	Date	SUITE #10 GREENBRIER, AR 72058 PH: (501) 679-2373 www.LaceyFPE.com		DRIVE #10 GREEN	BRIER, AR 72058.	A ← 0.9/07/12 No. 11321 CANIMINATION NO. 11321 CANIMINATION NO. ACTUAL NO. 11321 NO.	ARCHITECTS		www.taggarch.com		0		Date 9/7/12	Checked SWL	Drawn SWL	F-602 Dwg. 126 of 126	DEPARTMENT OF VETERANS AFFAIRS	
VA FORM 08-6231, OCT 1978 1	1	2	I	3	4	1	5	I	6		7		8		9		ĺ	10